

HASEGAWA ELECTRIC CO., LTD.

HEAD OFFICE:

5-8-17 Shioe, Amagasaki-city, Hyogo 661-0976 Japan

PHONE: +81-6-6429-6144 FAX: +81-6-6429-0016

Test Result

1. Test Item: Withstand Voltage Test

Sample No.	Test Specification	Test Result	Judgment
Standard for tested parts: 75 kV class			
H-02-01	AC 75 kV / 5 min No flashover and no smoke phenomenon	No abnormality	Pass
H-02-02	AC 75 kV / 5 min No flashover and no smoke phenomenon	No abnormality	Pass
H-02-03	AC 75 kV / 5 min No flashover and no smoke phenomenon	No abnormality	Pass

2. Explanation:

2.1 Based on CNS6653-80, CNS6654-80.

2.2 The specified test voltage does not include the tolerance of the test equipment.

3. Attention:

According to the “Electrical Safety Equipment Test Regulation” Article 272, the insulation protective equipment, insulation gloves, live working tools, etc., should be tested for insulation performance before use. Workers should conduct a self-inspection before use to ensure safety.